

CERTIFICATE

KEMA No.: **2114339.04**

Issued to:

Applicant:

Lamp 83

Yahya Kemal Mahallesi

34410, KAGITHANE/ISTANBUL, Turkey

Manufacturer/Licensee:

Lamp 83

Yahya Kemal Mahallesi

34410, KAGITHANE/ISTANBUL, Turkey

Products : luminaires for metal-halide lamps

Trade name : LAMP83

Types : L SP1402003, L SP1402004, L SP1410002, L SP1410002, L SP1902004

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

KEMA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standards EN 60598-1:2004 and EN 60598-2-1:1989
- an inspection of the production location according to CENELEC Operational Document CIG 021
- a certification agreement with the number 2114339

KEMA hereby grants the right to use the ENEC KEMA-KEUR certification mark.

The ENEC KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration of the ENEC KEMA-KEUR certification agreement and under the conditions of the ENEC KEMA-KEUR certification agreement.

This certificate is issued on: November 6, 2008 and expires upon withdrawal of one of the above mentioned standards.

KEMA Quality B.V.



drs. G.J. Zoetbrood
Managing Director

J. Bronsvort
Certification Manager

ACCREDITED BY
THE DUTCH COUNCIL
FOR ACCREDITATION



© Integral publication of this certificate is allowed

SPECIFICATION OF THE CERTIFIED PRODUCT

Product data

Product	:	luminaires for metal-halide lamps
trade name(s)	:	LAMP83
type(s)	:	L SP1402003 L SP1402004 L SP1410002 L SP1902004
rated voltage	:	230 V
nature of supply	:	ac
rated frequency	:	50 Hz
rated input	:	35 W, 70 W
lamp type	:	see product data per type
class	:	I
degree of protection	:	see product data per type
description	:	spotlight luminaires for metal halide lamp

Additional information

Luminaires are provided with F-marking.

Product data - type L SP1402003

description	:	PROSPOT
lamp type	:	HCI-T /G12
rated input	:	35 W, 70 W
degree of protection	:	IP20

Product data - type L SP1402004

description	:	PROSPOT
lamp type	:	HCI-TC/G8.5
rated input	:	35 W, 70 W
degree of protection	:	IP20

Product data - type L SP1410002

description	:	MEGASPOT
lamp type	:	HCI-T /G12
rated input	:	35 W, 70 W
degree of protection	:	IP20

Product data - type L SP1902004

description	:	NEOSPOT II
lamp type	:	HCI-T /G12
rated input	:	35 W, 70 W
degree of protection	:	IP30



TESTS

Test requirements

EN 60598-1:2004 +A1:2006

EN 60598-2-1:1989

Test result(s)

The test results are laid down in KEMA test file 2114339.04.

Remarks

This certificate supersedes the previous version of this certificate dated June 12 2008, due to extension of the rated input possibilities of the various types.

Conclusion

The examination proved that all test requirements were met.

Tested by : H.J. Brouwer

Checked by : P.G.M. Roelofs

Factory location

Lamp 83,

Yahya Kemal Mahallesi, 34410, KAGITHANE/ISTANBUL, Turkey